

PUBLIC WORKS DEPARTMENT (B & R), HARYANA



Office of the Executive Engineer,
Provincial Division, PWD B&R Br., Faridabad.
Tele - 0129-2288187
Email ID: pwd-eepd1-faridabad@hry.nic.in

No. 5712 Dated 06/8/19
To

The Principal,
St. Albans School,
Sector-15, Faridabad.

Subject:- NOC for building structure safety certificate for St. Albans School, Sector-15, Faridabad.

Reference:- Your office letter dated 24.04.2019..

In this connection of above cited subject, it is submitted that Sub Divisional Engineer Provincial Sub Division No.3, PWD B&R Br. Faridabad along with concerned Junior Engineer inspected the site on 18th July, 2019. The inspection fees of site has deposited by the applicant vide GRN No.0047928904 dated 28.02.2019 and the structure stability certificate from M/s Rakesh Bhatia & Associates Office-cum-Res. 1-D/129, NIT Faridabad was submitted on 24.06.2019 by the school authorities. The following are observations of the building during the inspection of the school :-

GROUND FLOOR:-

- At ground floor there are 01 No. Admin Block, 01 No. staff room, 01 No. Seminar Hall, 10 Nos. classrooms, 01 No. Medical Room, 01 No. Staff Office, 01 No. Head Mistress Office, 03 No. toilets, 02 Nos. stair cases, 01 No. MS staircase upto first floor only exist in the school premises.

FIRST FLOOR:-

- At first floor level there are 14 Nos. classrooms, 01 No. staff room, 01 No. Counseling room, 01 No. Science Lab, 01 No Computer Lab, 02 Nos. staircase, 03 Nos. toilets, exist in the school premises.

SECOND FLOOR:-

- At second floor there are 11 Nos. classrooms, 01 No. Dance rooms, 01 No. SST Lab, 01 No. Path Lab, 01 No. Librarian, 01 No. Co-ordinator Office, 03 Nos. toilets and 02 Nos. staircases exist in the school premises.

THIRD FLOOR:-

- At third floor there are 09 Nos. classrooms, 01 No. toilet, 02 Nos. Sport room and 02 Nos. staircases exist in the school premises.

The building is having frame structure with column beams and R.C.C. slab. The structure stability certificate has been also enclosed, which issued by RAKESH BHATIA & ASSOCIATES Office-cum-Res. 1-D/129, NIT Faridabad dated 20.06.2019. The fire NOC has also been issued to the concern school vide Sr. Fire Station officers Faridabad memo. No.F.S.O/2017/F-967/1326 dated 16.10.2017 valid upto 15.06.2022. The hygiene certificate is also issued vide Civil Surgeon, Faridabad office No. SH/2018/875 dated 24.12.2018 valid upto 31.03.2019. Some alterations done by the school authorities like 01 No. staircase shown in the drawing submitted by them but no staircase found at the site.

The structure of building is framed with R.C.C. columns, beams and slab. Keeping in view all the circumstances the building is seems to be safe. The building safety certificate may be issued subject to periodical inspections.

DA/-Nil



Executive Engineer,
Provincial Division,
PWD B&R Br Faridabad.

Endst. No

Dated

A copy of the above is forwarded to the Sub Divisional Engineer, Provincial Sub Division No.3, Faridabad for information w.r. to his office memo No.1615 dated 26/07/2019.

DA/-Nil


Executive Engineer,
Provincial Division,
PWD B&R Br. Faridabad


Headmistress
St. Albans School
Sector-15, Faridabad


MANAGER
ST. ALBANS SCHOOL
SECTOR-15, FARIDABAD